



SPARK ARRESTER

FIRE DEPARTMENT STANDARDS

Arresters shall have a vertical height of not less than five (5) inches above the top of the flue.

Spark arrester top and sides shall be constructed of galvanized mesh with a minimum of sixteen (16) gauge and a maximum of twelve (12) gauge. Openings shall not exceed one-half (1/2) inch and not closer than three-eighths (3/8) inch. All seams shall be overlapped one (1) inch.

Arresters shall be securely fastened to the top of the chimney with a flange or securely fitted inside.

